

ANNUAL NITRATE / NITRITE TESTING OF ALL TREATMENT PLANT WATER

SUPPLY	SOURCE CODE	LOCATION		Oct-13		Oct-14		Dec-15		Dec-16		Nov-17		Nov-18
			MAV	Nitrate N	Nitrate N	Nitrate N	Nitrate N	Nitrate N	Nitrate N	Nitrate N				
Amberley	G01997	Ashworth Road SH1	11.3	<0.002		<0.05		<0.05		<0.05		<0.05		<0.01
Ashley	G00139	Lower Sefton Road	11.3	0.32		0.23		0.19		0.11		0.25		0.19
Amberley/Ashley	G01817	Racecourse Road	11.3	0.49		0.48		0.45		0.46		0.49		0.49
Cheviot	G00179	Levin Road	11.3	0.23		0.24		0.16		0.14		0.33		0.27
Waiau	G01053	Waiau Road (by bridge)	11.3	0.38		0.24		0.23		0.31		0.58		0.51
Hanmer Springs	S00642	Thomas Hanmer Drive	11.3	0.021		<0.05		0.021		<0.05		<0.05		<0.01
Culverden	G01710	Culverden Road SH7	11.3	2.6		2.9		3.1		3.2		3.1		3.14
Haw / Waikari	G01096	Bakers Ford booster	11.3	0.77		0.74		0.77		0.5		0.72		0.93
Waipara	G02158	Waipara Service Station	11.3	3.3		3.5		3.6		3.9		3.5		3.68
Hurunui No.1	G00143	1324 Greta Road (SH1)	11.3	0.111		0.34		0.21		0.15		0.28		0.38
Parnassus	G00651	Main Well SH1	11.3	0.33		0.21		0.33		0.18		0.34		0.26
Kaiwara	S01059	Cat Hill Road	11.3	0.198		0.21		0.198		0.16		0.56		0.31
Kowai River	G01382	Kowai River Road	11.3							<0.05		0.09		0.04
Waiau Rural	S00537	River Road	11.3	0.142		0.35		0.24		0.46		1.67		1.03
Amuri Plains	G00649	Caithness Road	11.3	1.03		0.31		1.01		0.48		0.43		0.43
Balmoral (cl)	S00533	Cascade Road	11.3	0.031		0.07		0.05		0.07		0.11		0.02
Lower Waitohi	S00534	280 Gilberts Road	11.3	1.63		1.48		0.88		0.92		2.1		1.84
Peaks	S00513	258 Creans Road	11.3	3.3		2.1		0.36		0.16		0.18		0.63
Upper Waitohi	S00536	841 Lake Sumner Road	11.3	0.129		0.07		<0.05		0.1		0.05		0.21
Leithfield Bch	G02119	Lucas Drive	11.3	<0.002		<0.05		<0.05		<0.05		<0.05		<0.01
Blythe	S00511	Riverview Road	11.3	0.97		0.47		0.82		1.68		1.1		1.37

NOTES

MAV

Maximum Acceptable Value

